

Case 1 1
Cause 1
Solution 1

ls, mecapion, safeop, alstate,

LS MECAPION : SafeOP

× LS MECAPION Driver SafeOP

Case 1

Cause

- XML ¹⁾ SM2, SM3 Enable="0"

```
<Sm MinSize="64" MaxSize="192" DefaultSize="128" StartAddress="#x1000" ControlByte="#x26" Enable="1">MBoxOut</Sm>
<Sm MinSize="64" MaxSize="192" DefaultSize="128" StartAddress="#x1400" ControlByte="#x22" Enable="1">MBoxIn</Sm>
<Sm DefaultSize="12" StartAddress="#x1800" ControlByte="#x64" Enable="0">outputs</Sm>
<Sm DefaultSize="20" StartAddress="#x1c00" ControlByte="#x20" Enable="0">inputs</Sm>
```

Solution

- Enable="1"

1)

LS Mecapion L7N_V0.03e.xml

From:

<http://comizoa.com/info/> - -

Permanent link:

http://comizoa.com/info/doku.php?id=platform:ethercat:70_users_guide:20_ts:ls_safeop_failed&rev=1564387131

Last update: **2024/07/08 18:22**